

## IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

ESTE INFORME CONTIENE INFORMACIÓN IMPORTANTE ACERCA DE SU AGUA POTABLE. HAGA QUE ALGUIEN LO TRADUZCA PARA USTED, O HABLE CON ALGUIEN QUE LO ENTIENDA.

South Well # 2, Entry Point # 102 Has Levels of Tetrachloroethylene  
Above Drinking Water Standards

Our water system recently violated a drinking water standard. Although this incident was not an emergency, as our customers, you have a right to know what happened and what we did to correct this situation.

We routinely monitor for drinking water contaminants. Testing results we received on 03/12/2010 show that our system exceeds the standard, or maximum contaminant level (MCL), for Tetrachloroethylene. The standard for Tetrachloroethylene (PCE) is 0.005mg/L or 5 parts per billion. PCE was found at 0.0058mg/L or 5.8 parts per billion (ppb). A check sample result we received on 03/23/2010 was found at 0.0079mg/L or 7.9 ppb. The average result was found at 6.85 ppb.

### What should I do?

**You do not need to use an alternative (e.g., bottled) water supply.** However, if you have specific health concerns, consult your doctor.

### What does this mean?

This is not an immediate risk. If it had been, you would have been notified immediately. However, some people who drink water containing Tetrachloroethylene in excess of the MCL over many years could have problems with their liver, and may have an increased risk of getting cancer.

**What happened? What was done?** During required quarterly sampling of Volatile Organic Chemicals (VOC's), at **South Well #2, entry point # 102, located in the Estates of Doylestown**, sample results for Tetrachloroethylene (PCE) showed levels at 5.8ppb and 7.9ppb. Further sampling will be performed.

For more information, please contact Scott Miele, Chief Water Operator at 215-348-9915 x1045.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

This notice is being sent to you by Doylestown Township Municipal Authority (DTMA).

PWS ID#: 1090128

Date distributed: 03/26/2010

This Public Notification pertains ONLY to water customers of Doylestown Township Municipal Authority and ONLY for those customers that reside in DTMA's South Water System. The South Water System is:  
THE ESTATES OF DOYLESTOWN. THE GREENS. BARN PLAZA. POINT PLAZA. BLUEBERRY HILL.  
AAA-MID ATLANTIC. HOLBERTS VW.